


# CERTIFICATE OF CONFORMITY

Issued to: ALTENERGY POWER SYSTEM INC.  
Building 2, No.522, Yatai Road, Nanhu District, Jiaxing City, Zhejiang 314050, China

For the product: 3-phase Microinverter

Trade name:  **APsystems**

Type/Model: QT2, QT2-EU

Ratings: Operating temperature range: - 40°C to + 65°C  
Protective class: I  
Ingress protection rating: IP67  
Power factor range (adjustable): 0.8 leading...0.8 lagging  
PV input: max 60 Vdc, MPPT voltage range: 28-45 Vdc, Isc PV: 25 A x 4, max 20 A x 4  
AC output: 3/N/PE 400VAC, 50 Hz, max 2.9 A x 3, max 2000 VA

Manufactured by: ALTENERGY POWER SYSTEM INC.  
Building 2, No.522, Yatai Road, Nanhu District, Jiaxing City, Zhejiang 314050, China

Requirements: EN 50549-10:2022  
EN 50549-1:2019  
COMMISSION REGULATION (EU) 2016/631 (NC RfG)

This Test Certificate is granted on account of an examination by DEKRA, the results of which are laid down in a confidential file no. 6193326.50A and no. 6193326.50B

The examination has been carried out on one single specimen of the product. The Attestation does not include an assessment of the manufacturer's production. Conformity of this production with the specimen tested by DEKRA is not the responsibility of DEKRA.

This Test Certificate expires at the latest on 2029-11-05 or expires upon withdrawal of one of the above mentioned standards.

Shanghai, 2024-11-05

Certificate Number: 6193326.01COC

DEKRA Testing and Certification (Shanghai) Ltd.

  
Cliff Lin  
Certification Manager

© Integral publication of this certificate and adjoining reports is allowed



DEKRA Testing and Certification (Shanghai) Ltd.

No.250, Jiangchangsan Road, Jing'an District, Shanghai, 200436 People's Republic of China

T +86 21 6056 7600 F +86 21 6056 7555 [www.dekra-product-safety.com](http://www.dekra-product-safety.com)

ESA-CER-F021 v4.1